



OFFICE OF THE FIRE OFFICER,
KORAPUT CIRCLE, KORAPUT
(KORAPUT/NABARANGPUR/MALKANAGIRI/RAYAGADA)

Dtd. 11.11.2021

Letter No. 590 / KPT CrI .

To, The principal,
Bikash Vidyalaya, Gandhinagar, Koraput
Ref:- Online Fire Safety Application No. F5C1409290042022000045.

Sub:- Issuance of Fire Safety Certificate in respect of G+2 Storied Residential Building, Gandhinagar, Dist.-Koraput.

Madam,

With reference to the subject cited above this is intimate that as per rule 3(j) Of Odisha Fire Prevention and Fire Safety (Amendment) Rules, 2019, the following Education Building are only required to obtain Fire Safety Certificate.

1. Having height of 12 mtr.and above or,
2. Having a built-up area of 1000 square meters or above, or
3. Having 03 storied buildings.

However,under taken verification by a team of fire service officer on 11.11.2021, Bikash Vidyalaya, Gandhinagar, Koraput is suitable over Gandhinagar, dist.-Koraput, contains 01 block having G+2 floors, total built-up area = approx.6434Sq. mt And height- approx.11.9 mtr.


Hence, as per provision of rule 3(j) of odisha prevention and fire safety (Amendment) Rules, 2019, fire safety certificate (F.S.C) is not required to the afore-said educational building as on date of verification i.e 11.11.2021.

However, 06 nos of ABC (6kgs), Fire Extinguisher, has been installed which was found working condition during verification.

This Certificate is valid for 2 years (10.11.2023)

Here with your application is disposrd of accordingly.

Yours Faithfully


Deputy Fire Officer
Koraput Circle, Koraput
Koraput Circle, Koraput